

Certificate

of
Continued Compliance

No: 202350038/AA/00

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **AX PRO 96 input control panel**
Trademark: **HIKVISION**
Type designation: **DS-PWA96-M-WE**
Serial No: **Q01820260**
Hardware / Software version: **PCB101226600 19131 Rev1.2 / V1.2**
Variants: **See Annex 3**

Manufacturer: **Hangzhou Hikvision Digital Technology Co.,Ltd.**
Address: **No.555 Qianmo Road,**
City: **Binjiang District | Hangzhou**
Country: **China**

This certificate is granted to:

Name: **Hangzhou Hikvision Digital Technology Co.,Ltd.**
Address: **No.555 Qianmo Road,**
City: **Binjiang District | Hangzhou**
Country: **China**

Expiry date: **14 August 2024**

This certificate has THREE Annexes.

Zevenaar, 14 August 2020



Marcellino Jansen
Test Engineer



Remarks and observations

The following conditions are applicable:

Security grade: 2
Environmental class: II
Equipment class: Fixed
Power supply type: A
ATS class: DP2
Notification requirements: C, E, F

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:
Hangzhou Hikvision Digital Technology Co., Ltd.
No. 299 Qiushi Road, Tonglu County
Hangzhou
China

Product inspection location:
Hikvision Europe B.V.
Dirk Storklaan 3
2132 PX, Hoofddorp
The Netherlands

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 200201660-001-Ver 1.00, 29 July 2020
- Telefication B.V.: 200201660-002 Ver 1.00, 29 July 2020
- Telefication B.V.: 200201660-004-Ver 1.00, 17 July 2020
- Telefication B.V.: 200201660-005-Ver 1.00, 10 August 2020
- Telefication B.V.: 200201660-ENV-Ver 1.00, 29 July 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009
EN 50131-5-3	March, 2017
EN 50136-2	August, 2013

Applied Standards

EN 50131-6	October, 2017
EN 50130-5	June, 2011
EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014
EN 50136-1+A1	November, 2018

The product as described in this certificate includes the following type designations:

- Product description: AX PRO 96 input control panel
- Trademark: HIKVISION
- Type designation: DS-PWA96-M-WE
- Hardware version: PCB101226600 19131 Rev1.2
- Software version: V1.2
- Serial number: Q01820260

- Product description: AX PRO 64 input control panel
- Trademark: HIKVISION
- Type designation: DS-PWA64-L-WE
- Hardware version: PCB101226600 19131 Rev1.2
- Software version: V1.2